

EC Type-Examination Certificate

Number 5982 Issue 1 Extension 1

This is to certify that the product group reference FA 50 215 50 / FA 50 216 55 comprising the following products:

Product Ref.	Description
FA 50 215 50	Steel scaffold hook Gate opening of 50mm Static strength of 23kN
FA 50 216 55	Steel scaffold hook Gate opening of 55mm Static strength of 23kN

Classification:

EN 362:2004 Class B

Technical reports

SATRA: SPC0205641/1227/1


has been subject to an EC Type-examination in accordance with Article 10 of the PPE Directive (89/686/EEC) and has been shown to satisfy the relevant provisions of this Directive for the Complex category through:

- i Testing to the following standard: EN 362:2004
- ii Examination of the relevant technical documentation.

You are therefore licensed to mark the product(s) listed above in accordance with Article 13 of Directive (89/686/EEC) and any relevant amending Directives once you have drawn up an EC declaration of product conformity. Please note that:


1. Full details of the certification and product are contained in the manufacturer's technical file
2. This certificate is only valid if embossed with the text – "SATRA – European Notified Body 0321"
3. This certificate is issued subject to the conditions on the reverse side of this certificate
4. CE marking of production is also reliant on current compliance with Directive 89/686/EEC Article 11

Signed:



(A Tamkin)

Signed:



Date: 7th June 2013

On behalf of SATRA